

TYPE APPROVAL CERTIFICATE N. FPE328923CS/002

This is to certify that the product identified below satisfies the requirements of the standard quoted under "Reference standard"

Descrizione	IMPIANTO FISSO DI ESTINZIONE INCENDIO A POLVERE
	CHIMICA
Tipo	DRY CHEMICAL POWDER ABC FIRE EXTINGUISHING
	SYSTEM SERIES "MARE-PW" and "MARE-PW EASY"
Richiedente	EMME ANTINCENDIO S.R.L.
	VIA DEL MOLINO 40 - LOC. CORSALONE
	52010 Chiusi Della Verna (AR)
	ITALY
Fabbricante	EMME ANTINCENDIO S.R.L.
Luogo di produzione	VIA DEL MOLINO 40 - LOC. CORSALONE
	52010 Chiusi Della Verna (AR)
	ITALY
Norme di riferimento	ISO 9094:2015
Documenti di riferimento	Rules for the Type Approval of Fixed Clean Agent
	Fire-Extinghishing Systems in Machinery Spaces

Rilasciato a Genova il 24 Novembre 2023. Questo Certificato è valido fino al 23 Novembre 2028

Davide Campora

RINA Services S.p.A.

Questo Certificato e' composto di 1 pagina e di 1 allegato

TYPE APPROVAL CERTIFICATE No. FPE328923CS/002

Enclosure - Page 1 of 2

DRY CHEMICAL POWDER ABC FIRE EXTINGUISHING SYSTEM SERIES "MARE-PW" and "MARE-PW EASY"

Product description

Dry chemical powder ABC fire-extinguishing system for machinery space with the following main characteristics:

System characteristics						
	Trade name	MARE-PW	MARE-PW EASY			
Powder container Components		One cylinder stored into the protected space upside.	One cylinder stored into the protected space upside down.			
	Discharge devices and distribuition.	Discharge valve assembled on the cylinder connected by alloy pipes with two discharge nozzles.	Discharge sprinkler valve on connected.	the cylinder		
System activation		Manual activation with steel wire or remote control/Automatic (68-93 °C).	Manual activation with steel wire or remote control/Automatic (68-93 °C).			
Extinguishing agent		Dry chemical powder ABC				
Installation requirements						
Powder quantity (kg)		Max gross volume c the protected space ()		Nozzles (MARE-PW only).		
1		1.5	2	2		
2		3.5	3	2		
3		5.1	4	2		
4		7	4	2		
6		10	5	2		
8.8		15	6	2		
11.7		20	8	2		

*pipes made of copper (10x1mm).

The system has to be installed, used and maintained in accordance with the manual(s) for installation, use and maintenance listed in the Reference documents.

Field of application

A and B Class fires in unmanned machinery spaces of pleasure vessels having a length not exceeding 24 m and machinery spaces with a gross volume not exceeding 20 m³, to which Directive 20141/90/EU as amended is not applicable. Temperature range: from -20 °C to +93 °C.

Reference documents

- \bullet Technical Manual Plant MTI 00 Rev 0 issued on 20/10/2023 by Emme Antincendio Srl and filed by RINA with n° CSST-21931;
- Layout installation diagram system issued by Emme Antincendio Srl and filed by RINA with n° CSST-21782;
- Nozzle for fixed fire extinguishing system MARE, drawing n° 2163-2, issued by Emme Antincendio Srl and approved by RINA with n° CSST-21788;

RINA Services S.p.A. Via Corsica, 12 - 16128 Genova Tel +39 010 53851 Fax +39 010 5351000 • Valve for fixed fire extinguishing system MARE-PW, drawing n°EP_1906_D1, issued by Emme Antincendio Srl and

approved by RINA with n° CSST-21785;

• Sprinkler Valve for fixed fire extinguishing system MARE-PW EASY, drawing n° 2133-1, issued by Emme Antincendio Srl and approved by RINA with n° CSST-21786.

Tests carried out

• Fire tests n°2023CS013289/005-006-007-008 witnessed and filed by RINA with n° CSST-21784.

TYPE APPROVAL CERTIFICATE No. FPE328923CS/002

Enclosure - Page 2 of 2 DRY CHEMICAL POWDER ABC FIRE EXTINGUISHING SYSTEM SERIES "MARE-PW" and "MARE-PW EASY"

Remarks

For vessels classed by RINA :

- 1. the release device shall be readily accessible and operable;
- 2. a visual indication of discharge shall be provided;
- a pre-alarm system shall sound before the system is released (external supply to the system);
 automatic release of the system, in machinery spaces, where personnel is expected to work, having a gross volume above 15 m³ is not accepted;
- 5. aentilation openings serving the protected space shall be provided with means of closure operable from outside the protected space.

For vessels certified in accordance with Directive 2013/53/EU in lieu of what in the above items 1) to 5) the systems shall be installed in compliance with the requirements contained in ISO 9094:2015.

Manual release device shall be readly accessible and operable using a maximum force of 100 N. A label showing how to discharge the system shall be provided immediately adjacent to the release device, with the protected space(s) identified. A means of preventing accidental discharge shall be provided.

Mass produced articles of the aforesaid material are to be marked or labelled with the trade name and the data of the Company to whom this Certificate is addressed. The validity of this Certificate is dependent on the compliance of each manufactured product with the prototype which underwent the type approval tests and such compliance shall be stated

by the manufacturer. Moreover, the Company is fully responsible for ensuring compliance by performing all the necessary checks also in respect of its sub-suppliers. Notwithstanding the above, RINA reserves the right to make any checks it

deems appropriate during production. The validity of this Certificate ceases in the case of amendments to the rules on the basis of which the Certificate was issued.

Genoa 11/24/2023